

SAFE DRINKING WATERNO. 196Date: 27/04/2026

It is certified that an Inspection team headed by **UDAY CHAND RAM**, (Name of Officers with designation) from ASSISTANT ENGINEER, P.H. SUB DIVISION , GAYAJI (Name of department/Office) inspected the **GYAN BHARTI GLOBAL ~~PUBLIC~~ SCHOOL, ORE CHAKAND, P.S.-BELAGANJ. DISTRICT – GAYA JI (BIHAR) 804403** (Name & Address of the School) on 10.04.2026 and on the basis of Water Test Report (attached) bearing no. 11/2026.dated 16.04.2026 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till ONE YEAR.

Signature: 27/04/26Name: 27/04/2026 (UDAY CHAND RAM)

Designation: ASSISTANT ENGINEER

Name & Add. Of Department/

Office: P.H. SUB DIVISION,
GAYA JI WEST, GAYA JI

Assistant Engineer
P.H. Sub Division, Gaya West
Gaya

To,

**GYAN BHARTI GLOBAL PUBLIC SCHOOL,
ORE CHAKAND, P.S.-BELAGANJ.
DISTRICT – GAYA JI (BIHAR) 804403
(Name & Address of the Institution)**

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :	Raviranjana k.singh	G. YAN BHARTI GLOBAL SCHOOL							Sample Received on : 10/04/26										
Sample no	Block Name	Panchayat at Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+/-)	Remarks
1	BELAGANJ	NEYURI	RAMANAND BIGHA	-	0.95	130	84	48	11.22	0.12	10.01	64	0.36	6.93	-	-	5	Absent	
Reporting Date :	16.04.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
Permissible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	

*NR-No Relaxation.,BDL-Below Detection Limit

Ravi Kant
Chemist 16.04.26

P.H.Division, Gaya

जल नमूना का संग्रह दिनांक..10.04.26
Raviranjana के द्वारा किया गया है।